



केन्द्रीय विद्युत अनुसंधान संस्थान

(भारत सरकार की सोसाइटी, विद्युत मंत्रालय)

प्रो सर सी. वी. रामन रोड़, सदाशिवनगर डाक घर, पो. बा. सं. 8066, बेंगलूर - 560 080

CENTRAL POWER RESEARCH INSTITUTE

(A Govt of India Society under Min. of Power)

Prof. Sir C.V. Raman Road, Sadashivanagar P.O., P.B. No. 8066, Bangalore - 560 080, India

वेबसाइट/website : <http://www.cpri.in>

ENERGY EFFICIENCY AND RENEWABLE ENERGY DIVISION

Phone/Tele fax: 080-23604682 email: msb@cpri.in, ered@cpri.in

CPRI/ERED/SPV/2015

04/03/2015

To,

M/s. Solar Idea Pvt. Ltd.,
H. No. 8-2-277/A/7,
Plot No. 126, Road No. 2,
Banjara Hills, Hyderabad, Telangana 500034

Dear Sir,

Please find enclosed the test report for the following:

1. Efficiency and Environmental test report as per IEC 61683 for 1 kVA/1kW sine wave Solar PCU – 1 No.

Please acknowledge the receipt of the test report. Thank you for utilizing our services.

Corrections, if any, in the report may please be brought to our notice within 45 days from the date of issue of the report.

Kindly arrange to take back the equipment tested within 15 days, failing which the same will be disposed off as per CPRI rules.

Thanking you,

Yours Sincerely,

(M. Siddhartha Bhatt)
Additional Director

CPRI

TEST REPORT



**CENTRAL POWER RESEARCH INSTITUTE
(A Govt. Of India Society)
P.B. No. 8066, Sadashivanagar Post Office
Sir C.V. Raman Road
Bangalore – 560080 (INDIA)**




CPRI

TEST REPORT

Test Report Number : CPRI/ERED/INV/3613/2015 Date : 04/03/2015

Name and address of the customer	: Solar Idea Private Limited H NO 8-2-277/A/7, Road No. 2, Banjarahills, Hyderabad-500 034
Name and address of the manufacturer	: Same as above
Particulars of the sample tested	: 1000 VA Inverter/UPS
Condition of the sample on receipt	: New
Type	: 103-SOLAR UPS
Designation	: 24 Volt DC input, 1kW Power Conditioning Unit
Serial Number	: 00306/15
Number of sample tested	: One set
Date(s) of test(s)	: 19/01/2015 to 02/03/2015
CPRI Sample Code No(s)	: 2015EREDINVS419-2
Particulars of the test conducted	: Environmental test as per manufacturer request IEC 60068-2-30: 2005, IEC 60068-2-14: 2009 IEC 60068-2-1: 2007, IEC 60068-2-: 2007
Test accordance with Standard/specification	: IEC 60068-2-30: 2005, IEC 60068-2-14: 2009 IEC 60068-2-1: 2007, IEC 60068-2-: 2007
Sampling Plan	: Submitted by the Manufacturer
Customer's Requirement	: Environmental test as per manufacturer request IEC 60068-2-30: 2005, IEC 60068-2-14: 2009 IEC 60068-2-1: 2007, IEC 60068-2-: 2007
Deviation if any	: Nil
Name of the witnessing persons	: Nil
Customer Representative	: Nil
Other than Customer Representative	: Nil
Test(s) subcontracted with	: Nil
Address of the laboratory	: Nil
Documents constituting this report (in words)	
Number of sheets	: Nine
Number of oscillogram/s	: Nil
Number of Photos	: Two
Number of test circuit diagrams	: Nil
Number of drawings	: Nil

R. Sudhir Kumar
04/03/15
R. Sudhir Kumar
Test in-charge



(M. Siddhartha Bhatt)
(M. Siddhartha Bhatt)
Additional Director

CENTRAL POWER RESEARCH INSTITUTE



Test Report Number : CPRI/ERED/INV/3613/2015 Date : 04/03/2015

CPRI

1.0 DESCRIPTION OF POWER CONDITIONING UNIT

Sl. No.	Particulars	Details
1.1	Power rating	1 kW
1.2	Input voltage DC	24 V DC
1.3	Output AC	220±5 V, 50 Hz
1.4	Power factor	0.8 lag to Unity (1)
1.5	Model	103- Solar UPS/INV
2.0 Particulars of test conducted		
2.1	Climatic Test	
2.1.1	Damp Heat Cyclic Test IEC 60068-2-30: 2005	Damp Heat Cyclic Test (12 h+12 h cycle) IEC 60068-2-30: 2005 Test Db: 25 °C to 55 °C ± 2 °C variant-1 (12 h + 12 h cycle) – 24 hours per cycle. No. of cycles: Two
2.1.2	Change of temperature test IEC 60068-2-14: 2009.	Change of temperature test – IEC 60068-2-14: 2009. Test Nb Cl. 8. 0 Each temperature Cycle : -5 °C ± 2 °C for one hour and +55 °C ± 2 °C for one hour with rate of change at 1 °C/min No. of cycles: five
2.1.3	Cold test IEC 60068-2-1: 2007	Cold test as per IEC 60068-2-1: 2007 Test Ab Cl. 5.2 & Cl. 6.0: -10 °C ± 2 °C for two hours
2.1.4	Dry Heat Test IEC 60068-2-: 2007	Dry Heat Test as per IEC 60068-2-: 2007 Test Bb Cl. 5.2 & Cl. 6.0 + 55 °C ± 2C for 16 hours No. of cycles – One
2.1.5	Functional Test	Functional test as per customer request to be conducted after each climatic test
2.1.6	Visual Examination	Visual examination to be conducted after each climatic test.
2.1.7	Insulation Resistance Test	Insulation resistance test to be done after completion of all tests


Test in- Charge


Test Engineer



Test Report Number : CPRI/ERED/INV/3613/2015 Date : 04/03/2015

TEST RESULTS

The test sample was mounted within the working space in environmental test chamber at ambient temperature. A view of the test sample is as shown in Photographs

1. DAMP HEAT CYCLIC TEST

(As per IEC60068 2-30 Ed. 2005 Variant 1 and customer's request)

- a. Initial stabilization of test sample is carried out at 25 °C ± 3 °C and RH 75 %
- b. After stabilization, RH is increased to 95 % maintaining the temperature at 25 °C ± 3 °C in one hour.

c. Conditioning

Step No.	Environmental Test profiles steps	Duration
1.	Changing condition from 25 °C to 55 °C with RH above 95 % (Ramp time 10 °C/hr.)	3 hours
2.	Maintaining the condition of 55 °C ± 2 °C at RH between 90 % and 96 %	9 hours
3.	Changing condition from 55 °C to 25 °C with RH above 95 % (Ramp time 10 °C/hr.)	3 hours
4.	Maintaining the condition of 25 °C at RH above 95 %	9 hours

The above 4 steps constitutes one cycle.

No. of cycles performed: 2

- d. On completion of damp heat cycles, RH is reduced from 95 % to 75 % in less than 1 hour with chamber temperature 25 °C ± 3 °C

e. Recovery period


Sample is kept inside the chamber for recovery for 2 hours at 25 °C and 75 ± 2 % RH


f. Functional Test

Applied Voltage across the positive and negative terminals at input side	24 V (DC)
The inverter switch at the front panel shall be kept in 'ON' position and check output	ON
AC voltage across AC output terminals	219.3 V (AC)
Status of lamp connected across AC output terminals	Lamp On

g. Visual Examination

On visual inspection with naked eye, no visible physical damages / deterioration are observed.


Test in- Charge


Test Engineer



CPRI

Test Report Number : CPRI/ERED/INV/3613/2015 Date : 04/03/2015

TEST RESULTS

2. CHANGE OF TEMPERATURE TEST

(As per IEC60068- 2- 14 Ed. 2009 Test Nb Cl. 8. 0 and customer's request)

The test sample was mounted within the working space in environmental test chamber at ambient temperature.

a. Conditioning

Step No.	Environmental Test profiles steps	Duration
1.	Changing temperature from 25 °C (ambient) to -5 °C at rate of 1 °C / min	30 min.
2.	Maintaining the temperature of -5 °C	1 hour
3.	Changing temperature from -5 °C to 55 °C at rate of 1°C/ min	1 hour
4.	Maintaining the temperature of +55 °C	1 hour
5.	Changing temperature from 55 °C to 25 °C (ambient) at rate of 1°C/ min	30 min.

The above 5 steps constitutes one cycle.

No. of cycles performed: 5

b. Recovery period

On completion of the test cycles, the test condition is maintained at standard atmospheric conditions of 25 ± 2 °C & <50 % RH 2 hours recovery period

c. Functional Test

Applied Voltage across the positive and negative terminals at input side	24 V (DC)
The inverter switch at the front panel shall be kept in 'ON' position and check output	ON
AC voltage across AC output terminals	216.2 V (AC)
Status of lamp connected across AC output terminals	Lamp On

d. Visual Examination

On visual inspection with naked eye, no visible physical damages / deterioration are observed.

Test in- Charge

Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



Test Report Number : CPRI/ERED/INV/3613/2015 Date : 04/03/2015

TEST RESULTS

CPRI

3. COLD TEST

(As per IEC60068- 2- 1 Ed. 2007 Test Ab Cl. 5. 2 & Cl. 6 and customer's request).

The test sample was mounted within the working space in environmental test chamber at ambient temperature.

a. Conditioning

Step No.	Environmental Test profiles steps	Duration
1.	Changing temperature from 25 °C (Ambient) to -10 °C at rate of 1 °C / min	35 min.
2.	Maintaining the temperature of -10 °C for temperature stability of sample	3 hours
3.	Maintaining the temperature of -10 ± 2 °C	2 hours

b. Recovery period

On completion of the test condition, the temperature was gradually raised to standard atmospheric conditions of 25 ± 2 °C & <50 % RH 2 hours recovery period

c. Functional Test

Applied Voltage across the positive and negative terminals at input side	24 V (DC)
The inverter switch at the front panel shall be kept in 'ON' position and check output	ON
AC voltage across AC output terminals	218.5 V (AC)
Status of lamp connected across AC output terminals	Lamp ON

d. Visual Examination

On visual inspection with naked eye, no visible physical damages / deterioration are observed.

Test in- Charge

Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



Test Report Number : CPRI/ERED/INV/3613/2015 Date : 04/03/2015

CPRI

TEST RESULTS

4. DRY HEAT TEST

(As per IEC60068-2-2 Ed. 2007 Test Bb Cl. 5. 2 & Cl. 6. 0 and customer's request)

The test sample was mounted within the working space in environmental test chamber at ambient temperature.

a. Conditioning

Step No.	Environmental Test profiles steps	Duration
1.	Changing temperature from 25 °C (Ambient) to 55 ± 2 °C at rate of 1 °C/ min with RH below 50 %	30 min.
2.	Maintaining the temperature of 55 ± 2 °C for temperature stability of sample	3 hours
3.	Maintaining the temperature of 55 ± 2 °C	16 hours

b. Recovery period


On completion of the test condition, the temperature was gradually lowered to standard atmospheric conditions of 25 ± 2 °C & < 50 % RH 2 hours recovery period


c. Functional Test

Applied Voltage across the positive and negative terminals at input side	24 V (DC)
The inverter switch at the front panel shall be kept in 'ON' position and check output	ON
AC voltage across AC output terminals	217.8 V (AC)
Status of lamp connected across AC output terminals	Lamp ON

d. Visual Examination

On visual inspection with naked eye, no visible physical damages / deterioration are observed.


Test in- Charge


Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



Test Report Number : CPRI/ERED/INV/3613/2015 Date : 04/03/2015

5. INSULATION RESISTANCE TEST

Insulation Resistance test was conducted within 30 minutes of recovery period after the completion of dry heat test with megger at a voltage of 500 V (DC).

Sl. No.	Test Connection	Measure Values (M Ω)	Specified Values (As per Customers Requirements) (M Ω)
1	Between shorted Battery Terminals (+ve and -ve) and grounded enclosure	75.6	>50
2	Between shorted AC terminals and grounded enclosure	80.1	>50
3	Between battery terminals and AC terminals shorted and grounded enclosure.	94.3	>50

Test in- Charge

Test Engineer

CENTRAL POWER RESEARCH INSTITUTE

Test Report Number : CPRI/ERED/INV/3613/2015 Date : 04/03/2015



CPRI

Test Chamber Details:

1. Work Space: 1m (H) x 1m (W) x 1m (D)
2. Temperature range : - 40 °C to 180 °C
3. Accuracy (Temp) : ± 1.0 °C
4. Humidity Range: 10 % RH to 98 % RH
5. Accuracy: ± 3 % RH
6. Serial No. KLS/0316/12-13
7. Model No. KEW/EC-40

Photographs of tested sample:



R. Srinivas

Test in- Charge

[Signature]

Test Engineer

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT




CPRI

Test Report Number : CPRI/ERED/INV/3613/2015 Date : 04/03/2015

NOTE

- a) The test results are only for the Item tested.
- b) Publication or reproduction of the test report/certificate in any form other than by complete set of the whole test report/Certificate and the language written is not permitted without the written consent of CPRI.
- c) Any corrections/erasure invalidates the test Report/Certificate.
- d) Any anomaly/Discrepancy in the test report/Certificate should be brought to the notice of CPRI within 45 days from the date of issue.
- e) The verification of the sample drawings by CPRI is limited to dimensional checks only wherever possible.


Test in- Charge


Test Engineer

CPRI

TEST REPORT



**CENTRAL POWER RESEARCH INSTITUTE
(A Govt. Of India Society)
P.B. No. 8066, Sadashivanagar Post Office
Sir C.V. Raman Road
Bangalore – 560080 (INDIA)**

CENTRAL POWER RESEARCH INSTITUTE



CPRI

TEST REPORT

Test Report Number : CPRI/ERED/INV/3612/2015 **Date : 04/03/2015**

Name and address of the customer : Solar Idea Private Limited
H NO 8-2-277/A/7, Road No. 2
Banjarahills, Hyderabad-500 034


Name and address of the manufacturer : Same as above

Particulars of the sample tested : 1000 VA Inverter
Condition of the sample on receipt : New
Type : 103-SOLAR UPS
Designation : 24 Volt DC input, 1kW Power Conditioning Unit
Serial Number : 00306/15
Number of sample tested : One set
Date(s) of test(s) : 19/01/2015 to 02/03/2015
CPRI Sample Code No(s) : 2015EREDINVS419-1
Particulars of the test conducted : Efficiency test as per IEC 61683

Test accordance with Standard/specification : Efficiency test as per IEC 61683
Sampling Plan : Submitted by the Manufacturer
Customer's Requirement : Efficiency test as per IEC 61683

Deviation if any : Nil
Name of the witnessing persons : Nil
Customer Representative : Nil
Other than Customer Representative : Nil
Test(s) subcontracted with : Nil
Address of the laboratory : Nil
Documents constituting this report (in words) : Nil
Number of sheets : Seven
Number of oscillogram/s : Nil
Number of Photos : Nil
Number of test circuit diagrams : Nil
Number of drawings : Nil

R. Sudhir Kumar
R. Sudhir Kumar
Test in-charge



(M. Siddhartha Bhatt)
(M. Siddhartha Bhatt)
Additional Director

CENTRAL POWER RESEARCH INSTITUTE



Test Report Number : CPRI/ERED/INV/3612/2015

Date : 04/03/2015

CPRI

DESCRIPTION OF POWER CONDITIONING UNIT

Sl. No.	Particulars	Details
01	Power rating	1 kW
02	Input voltage DC	24 V DC
03	Output AC	220±5 V, 50 Hz
04	Power factor	0.8 lag to Unity
05	Model	103- Solar UPS

TEST CONDITIONS & EQUIPMENTS

Sl. No.	Particulars	Details
01	Temperature during test	25 °C
02	Load	Electronic load (variable)
03	Power source	DC power source
04	Measuring Instruments	Power analyzers Make: HIOKI Sl. Nos. 130309616

Test in- Charge

Test Engineer

CENTRAL POWER RESEARCH INSTITUTE

Test Report Number : CPRI/ERED/INV/3612/2015

Date : 04/03/2015



CPRI

TEST RESULTS

1) No load Test: No load test is carried out as per IEC 61683 standard

- a) DC voltage : 24.05 V
- b) DC Current: 0.71 A
- c) Power: 17.07 W
- d) Energy recorded for 1 minutes: 0.28 Wh
- e) Observation: Nil

2) Efficiency test: As per IEC 61683 standard


a) Power efficiency

Measured voltage, voltage THD, current & current THD at AC side and voltage & current at DC side in stand-alone mode.

Sl. No.	Testing, % load	AC side				DC side	
		Voltage, V	Voltage THD, %	Current, A	Current THD, %	Voltage, V	Current, A
1	120%	219.51	6.17	5.50	5.10	24.06	60.13
2	100%	214.70	4.97	4.70	3.00	24.02	49.31
3	75%	215.24	4.88	3.48	2.65	24.09	35.37
4	50%	215.45	4.91	2.35	2.92	24.01	23.38
5	25%	217.69	3.72	1.15	5.43	24.09	11.55
6	10%	219.90	3.13	0.46	10.66	24.02	4.99

Measured power at AC & DC side and efficiency at peak power.

Sl. No.	Testing, % load	AC Power, W	DC Power, W	Efficiency, %
1	120%	1207.07	1446.67	83.44
2	100%	1008.67	1184.46	85.16
3	75%	748.40	852.03	87.84
4	50%	504.95	561.33	89.96
5	25%	249.68	278.16	89.76
6	10%	99.58	119.81	83.11


Test in- Charge


Test Engineer

CENTRAL POWER RESEARCH INSTITUTE

Test Report Number : CPRI/ERED/INV/3612/2015 Date : 04/03/2015



TEST RESULTS

b) Energy efficiency: Energy is logged for a period of one minute.

CPRI

Sl. No.	Testing, % load	AC Energy, Wh	DC Energy, Wh	Energy Efficiency, %
1	120%	20.14	24.14	83.43
2	100%	16.82	19.76	85.12
3	75%	12.48	14.21	87.83
4	50%	8.42	9.36	89.96
5	25%	4.15	4.63	89.63
6	10%	1.67	1.99	83.92

c) Weighted energy efficiency:

Weighted energy efficiency is calculated by considering energy consumption at 100 % (Full load), 75 % (3/4th load), 50 % (1/2th load) and 25 % (1/4th load) for a duration of one minute. The no load loss is also considered for a period of one minute.

$$\eta_{WT} = \frac{\sum P_{O_i} \cdot T_i}{\sum P_{I_i} \cdot T_i} = \frac{\sum P_{O1} \cdot T_1 + P_{O2} \cdot T_2 + P_{O3} \cdot T_3 + P_{O4} \cdot T_4}{P_{I0} \cdot T_0 + P_{I1} \cdot T_1 + P_{I2} \cdot T_2 + P_{I3} \cdot T_3 + P_{I4} \cdot T_4} = \frac{\sum E_{O1} + E_{O2} + E_{O3} + E_{O4}}{E_{I0} + E_{I1} + E_{I2} + E_{I3} + E_{I4}}$$

Where E_{O1} , E_{O2} , E_{O3} & E_{O4} AC energy output for one minute for full load, 3/4th load, 1/2th load and 1/4th load respectively in Wh, E_{I0} is the no load DC energy for a period of one minute and E_{I1} , E_{I2} , E_{I3} & E_{I4} DC energy output for one minute for full load, 3/4th load, 1/2th load and 1/4th load respectively in Wh.

$$\eta_{WT} = \frac{41.87 \cdot 100}{0.28 + 47.96} = \frac{41.87 \cdot 100}{48.24} = 86.79 \%$$

Test in- Charge

Test Engineer

CENTRAL POWER RESEARCH INSTITUTE

Test Report Number : CPRI/ERED/INV/3612/2015

Date : 04/03/2015



TEST RESULTS

3) Instantaneous readings

CPRI

a) At full load

MEAS SYSTEM FILE										2015-01-21 19:31:08		
Vector	CH1	CH2	CH3	CH4	Wave + Noise	Select	Efficiency	XY Graph			PAGE	
HSync	U2	1P2W	Sync	U1	U: Manu	300V	I: Manu	10A	OFF	OFF	5Hz	CF card memory
												USB memory
U_{dc1}	: 24.065	V	U_{rms2}	: 215.37	V	CH1 Range				4 items		
I_{dc1}	: 48.78	A	I_{rms2}	: 4.648	A	U Manu 30V				8 items		
λ_1	: 0.8181		λ_2	: -0.9991		I Manu 100A				16 items		
P_1	: 1.1620k	W	P_2	: 1.0002k	W	CH2 Range				32 items		
S_1	: 1.4204k	VA	S_2	: 1.0011k	VA	U Manu 300V						
f_1	: 0.0000	Hz	Q_2	: -0.0436k	var	I Manu 10A						
η_1	: 86.07	%	η_2	: 0.00	%	CH3 Range						
U_{thd2}	: 4.73	%	I_{thd2}	: 2.89	%	U Manu 30V						
						I Manu 20A						
						CH4 Range						
						U Manu 1.5k						
						I Manu 200A						
										Select		

b) 75 % load test

MEAS SYSTEM FILE										2015-01-21 19:30:02		
Vector	CH1	CH2	CH3	CH4	Wave + Noise	Select	Efficiency	XY Graph			PAGE	
HSync	U2	1P2W	Sync	U1	U: Manu	300V	I: Manu	10A	OFF	OFF	5Hz	CF card memory
												USB memory
U_{dc1}	: 24.085	V	U_{rms2}	: 215.35	V	CH1 Range				4 items		
I_{dc1}	: 35.27	A	I_{rms2}	: 3.467	A	U Manu 30V				8 items		
λ_1	: 0.8186		λ_2	: -0.9987		I Manu 100A				16 items		
P_1	: 0.8432k	W	P_2	: 0.7457k	W	CH2 Range				32 items		
S_1	: 1.0300k	VA	S_2	: 0.7467k	VA	U Manu 300V						
f_1	: 0.0000	Hz	Q_2	: -0.0377k	var	I Manu 10A						
η_1	: 88.44	%	η_2	: 0.00	%	CH3 Range						
U_{thd2}	: 4.82	%	I_{thd2}	: 2.70	%	U Manu 30V						
						I Manu 20A						
						CH4 Range						
						U Manu 1.5k						
						I Manu 200A						
										Select		

[Signature]
Test in-Charge

[Signature]
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE



Test Report Number : CPRI/ERED/INV/3612/2015 Date : 04/03/2015

TEST RESULTS

CPRI

c) At 50 % load test

MEAS SYSTEM FILE										2015-01-21 19:27:38		
Vector	CH1	CH2	CH3	CH4	Wave + Noise	Select	Efficiency	XY Graph			PAGE	
HSync	U2	1P2W	Sync	U1	U: Manu 300V	I: Manu 10A	OFF	OFF	Avg	Lowest	CF card memory USB memory	
U_{dc1}	: 24.012	V	U_{rms2}	: 215.61	V	CH1 Range U Manu 30V I Manu 100A				4 items		
I_{dc1}	: 23.40	A	I_{rms2}	: 2.342	A	CH2 Range U Manu 300V I Manu 10A				8 items		
λ_1	: 0.8211		λ_2	: -0.9981		CH3 Range U Manu 30V I Manu 20A				16 items		
P_1	: 0.5593k	W	P_2	: 0.5040k	W	CH4 Range U Manu 1.5k I Manu 200A				32 items		
S_1	: 0.6811k	VA	S_2	: 0.5049k	VA					Select		
f_1	: 0.0000	Hz	Q_2	: -0.0307k	var							
η_1	: 90.12	%	η_2	: 0.00	%							
U_{thd2}	: 4.92	%	I_{thd2}	: 2.99	%							

d) At 25 % load test

MEAS SYSTEM FILE										2015-01-21 19:26:24		
Vector	CH1	CH2	CH3	CH4	Wave + Noise	Select	Efficiency	XY Graph			PAGE	
HSync	U2	1P2W	Sync	U1	U: Manu 300V	I: Manu 10A	OFF	OFF	Avg	Lowest	CF card memory USB memory	
U_{dc1}	: 24.052	V	U_{rms2}	: 218.00	V	CH1 Range U Manu 30V I Manu 100A				4 items		
I_{dc1}	: 11.70	A	I_{rms2}	: 1.160	A	CH2 Range U Manu 300V I Manu 10A				8 items		
λ_1	: 0.8231		λ_2	: -0.9967		CH3 Range U Manu 30V I Manu 20A				16 items		
P_1	: 0.2807k	W	P_2	: 0.2521k	W	CH4 Range U Manu 1.5k I Manu 200A				32 items		
S_1	: 0.3410k	VA	S_2	: 0.2530k	VA					Select		
f_1	: 0.0000	Hz	Q_2	: -0.0207k	var							
η_1	: 89.83	%	η_2	: 0.00	%							
U_{thd2}	: 3.65	%	I_{thd2}	: 5.41	%							

R. Sahas
Test in- Charge

[Signature]
Test Engineer

CENTRAL POWER RESEARCH INSTITUTE

TEST REPORT

Test Report Number : CPRI/ERED/INV/3612/2015

Date : 04/03/2015



CPRI

NOTE

- a) The test results are only for the Item tested
- b) Publication or reproduction of the test report/certificate in any form other than by complete set of the whole test report/Certificate and the language written is not permitted without the written consent of CPRI
- c) Any corrections/erasure invalidates the test Report/Certificate
- d) Any anomaly/Discrepancy in the test report/Certificate should be brought to the notice of CPRI within 45 days from the date of issue
- e) The verification of the sample drawings by CPRI is limited to dimensional checks only wherever possible.

Test in- Charge

Test Engineer